

Tel: 24980626 Fax : 24902700 Email: kashing.project@gmail.com Website: www.kashingehk.com



PROJECT	REF	REV	ITEM CODE	
LOCATION	DATE		PAGE	

SANITARY WARE SPECIFICATION SHEET

Item Descriptions	Kita (PRC) 1/2" x 1/2" Copper alloy angle valve complies with: BSEN200: 2008,	Illustration/ Drawing
	BSEN1982:2008, BSEN12167:2016 &	
	AS/NZS4020: 2005 ;test report J24164R2	
Model	CP-18A	
Finish	Chrome Plated	
Material	Copper	
Manufacturer	Kita	
Source	Ka Shing Enterprises (H.K) Limted Mr. Ivan Lau / Mr. GilmanYuen	
Contact Tel/Fax	(852) 2498-0626 / (852) 2490-2700	
E-mail	kashing.project@gmail.com	
Website	www.kashingehk.com	
		WIII WIII WIII WIII WIII WIII WIII WII
		G1/2 37mm
		22mm

N	ote
---	-----

^{*} All information of the above is for the reference only. No prior notice is made if any changes.



水務署 Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號

Our ref. : (4) II

來函檔號 Your ref. (4) in WSD 3321/2022 T/J(438/2022)

電話

Tel.

傳真 Fax.

: 2824 0578

10 June 2022

Ka Shing Enterprises (HK) Ltd Unit A, 3/F., 30-38 Tsuen King Circuit, Waylee Ind. Centre, Tsuen Wan, N.T., Hong Kong

(Attn.: Mr Ivan LAU)

Dear Sir,



Approval of "KITA" Angle Valve (General Acceptance No. C20220496)

Your letters dated 21 April 2022 and 14 May 2022 refer.

Having considered the test report ref. RKSH008-1r2 issued on 13 May 2022 by Ideal Test Consultants Ltd., this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer:

玉環同泰銅業有限公司

Country of Origin:

the Mainland of China

Brand:

Kita

Details of Fitting:

1/2" x 1/2" Copper alloy angle valve

Model:

CP-18A

Body Markings:

KITA

Expiry Date:

20 March 2027





This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,

(YAU Hau Yin)

for Director of Water Supplies

Encl.

WSD 3321/1/82] - without catalogue c.c.

ME/MC

] - with soft copy only

Unit 18, 8/F., World-Wide Industrial Ctn, 43 - 47 Shan Mei Street, Fo Tan, N.T. H.K..

Tel: 3702 1986 Fax:3702 1987 Email: sunny@idealtest.com.hk

TEST REPORT

REPORT REFERENCE NO.

RKSH008-1r2

: (This report is issued to supersede the report with reference no.: RKSH008-1r1)

TITLE

Testing of angle valve

METHOD OF TEST

BSEN200: 2008, BSEN1982:2008, BSEN12167:2016

& AS/NZS4020: 2005

PERIOD OF TESTS

25th Nov., 2021 to 21st Mar., 2022

SAMPLE SUBMITTED BY

(Information below provided by client)

Ka Shing Enterprises (H.K.) Limited Unit A, 3/F, 30-38 Tsuen King Circuit,

Waylee Industrial Centre, Tsuen Wan, N.T.

DESCRIPTION OF SAMPLE :

1/2" x 1/2" Angle valve

BRAND

KITA

MODEL

CP-18A

BODY MARKING

KITA

MANUFACTURER

玉環同泰銅業有限公司

COUNTRY OF ORIGIN

China

SUMMARY OF RESULTS

(Definition of 'C' - Conformance, '' - No requirement, 'NC' - Non - Conformance & 'R' - Remainder)

Tested item/s		Remark
1. Dimensions		C
2. Leak tightness Characteristics		
2.1 Leak tightness of the obturator and of the tap upstream of the	obturator(s)	С
2.2 Leak tightness of the tap downstream of the obturator(s)		C
3. Pressure Resistance Characteristics		
3.1 Mechanical behaviour upstream of the obturator-Obturator i	n the closed position	С
3.2 Mechanical behaviour downstream of the obturator-Obturate		С
4. Hydraulic Characteristics		
4.1 Flow rate of supply system of Type 1		/
4.2 Flow rate of supply system of Type 2		/
5. Chemical Composition		
5.1 Metal component - Body	ra da se	C
5.2 Metal component – Part		C
5.3 Metal component – Cartridge		C
6. Metal extraction test for non-metallic materials – plastic parts	V	C
7. Extraction of metals from the sample - Surface of internal water page 1	assage	C

Date: 13/11/2022 Authorized signature:

(Director)



RESULTS: - (apply only to the sample tested)

1. DIMENSIONS

(BSEN200: 2008 Cl.6)

ID	Variable	Unit	Measured	Required	Remark
1	Nominal size	in	1/2 x 1/2	1/2 x 1/2	С
1	Body thickness	mm	2.0	/	/
Overall result					C

2. LEAK TIGHTNESS CHARACTERISTICS

2.1 Leak tightness of the obturator and of the tap upstream of the obturator(s)

(BSEN200: 2008 Cl. 8.3)

ID	Variable	Unit	Measured	Required	Remark
Valantania e con inclurare a resorrar direiro	Static pressure	bar	16	16±0.5	С
1	Duration	s	60	60±5	С
	Leakage		No	No	С
			0	verall result	C

2.2 Leak tightness of the tap downstream of the obturator(s)

(BSEN200: 2008 Cl. 8.4)

ID	Variable	Unit	Measured	Required	Remark
	Static pressure	bar	4	4±0.2	C
High	Duration	s	60	60±5	С
pressure	Leakage	and and 100	No	No	C
	Static pressure	bar	0.2	0.2±0.02	С
Low	Duration	s	60	60±5	C
pressure	Leakage	and 100	No	No	C
			Ov	erall result	C



3. PRESSURE RESISTANCE CHARACTERISTICS

3.1 Mechanical behaviour upstream of the obturator-Obturator in the closed position

(BSEN200: 2008 Cl. 9.4)

ID	Variable	Unit	Measured	Required	Remark
	Static pressure	bar	25	25±0.5	С
1	Duration	s	60	60±5	С
	Permanent deformation		No	No	C
			Ov	erall result	C

3.2 Mechanical behaviour downstream of the obturator-Obturator in the open position

(BSEN200: 2008 Cl. 9.5)

Variable	Unit	Measured	Required	Remark	
Flow rate	1/s	0.4	0.4±0.04	C	
Duration	s	60	60±5	С	
Permanent deformation	~~~	No	No	С	
Overall result					

4. HYDRAULIC CHARACTERISTICS

4.1 Flow rate of supply system of Type 1

(BSEN200: 2008 Cl. 10)

ID	Variable	Unit	Measured	Required	Remark
G-14	Dynamic pressure	bar	3	3±0.2	C
Cold	Flow rate	1/s	0.244	/	/
***************************************	Overall result				

Note: WSD has waived the minimum flow rate requirement per WSD Circular Letter No. 1/2010

4.2 Flow rate of supply system of Type 2

(BSEN200: 2008 Cl. 10)

ID	Variable	Unit	Measured	Required	Remark
G 11	Dynamic pressure	bar	0.1	0.1±0.02	C
Cold	Cold Flow rate	1/s	0.059	1	/
			Ove	erall result	1

Note: WSD has waived the minimum flow rate requirement per WSD Circular Letter No. 1/2010



5. CHEMICAL COMPOSITION

5.1 Metal component – Body

(Designation: BSEN1982:2008-CC754S)

ID	Variable	Unit	Measured	Required	Remark
	Cu – Copper	%	58.0	58.0 - 63.0	С
	Zn – Zinc	%	38.9	R	С
	Pb – Lead	%	1.8	0.5 - 2.5	С
	Sn — Tin	%	0.2	≤ 1.0	С
Body	Ni – Nickel	%	0.4	≤ 1.0	C
Bouy	Fe – Iron	%	0.3	≤ 0.7	С
	Al – Aluminium	%	0.4	≤ 0.8	С
	Mn – Manganese	%	0.09	≤ 0.5	C
	P – Phosphorus	%	0.01	≤ 0.02	С
	Si – Silicon	%	0.01	≤ 0.05	C
			Over	all result	С

5.2 Metal component – Part

(Designation: BSEN12167:2016-CW617N)

ID	Variable	Unit	Measured	Required	Remark
	Cu – Copper	%	57.2	57.0-59.0	С
	Zn – Zinc	%	40.1	R	С
	Pb – Lead	%	1.8	1.6-2.5	С
Deset	Sn – Tin	%	0.2	≤ 0.3	С
Part	Ni – Nickel	%	0.3	≤ 0.3	С
	Fe – Iron	%	0.3	≤ 0.3	C
	Al – Aluminium	%	0.01	≤ 0.05	С
	Others	%	0.09	≤ 0.2	С
			Over	all result	С

5.3 Metal component - Cartridge

(Designation: BSEN12167:2016-CW617N)

ID	Variable	Unit	Measured	Required	Remark
	Cu – Copper	%	57.2	57.0-59.0	C
	Zn – Zinc	%	40.2	R	С
	Pb – Lead	%	1.7	1.6-2.5	С
C	Sn – Tin	%	0.2	≤ 0.3	С
Cartridge	Ni – Nickel	%	0.3	≤ 0.3	C
	Fe – Iron	%	0.3	≤ 0.3	C
	Al – Aluminium	%	0.02	≤ 0.05	С
	Others	%	0.08	≤ 0.2	C
			Over	all result	С



6. METAL EXTRACTION TEST FOR NON-METALLIC MATERIALS – plastic parts

The non-metallic material was immersed in boiling de-ionized water for 5 ± 1 minutes in accordance with Clause 7.3 in BS 6920-3:2000.

The concentration of arsenic, lead, cadmium, chromium, selenium, nickel and antimony of extract were determined by the method specified in BS 6920-2.6:2000+A2:2014 against the maximum allowable values in WHO's Guidelines for Drinking Water Quality – Fourth Edition 2011.

ID	Variable	Unit	Measured	Required	Remark
	As - Arsenic	μg/l	< 1	≤ 10	С
	Pb - Lead	μg/l	< 3	≤ 10	С
	Cd - Cadmium	μg/l	< 1	≤3	С
Plastic parts	Cr - Chromium	μg/l	< 10	≤ 50	С
	Se - Selenium	μg/l	< 5	≤ 40	С
	Ni - Nickel	μg/l	< 10	≤ 70	C
	Sb - Antimony	μg/l	< 1	≤20	С
			Over	all result	C

Notes: -Requirements are based on WHO Guidelines for Drinking Water Quality Fourth Edition: 2011.

7. EXTRACTION OF METALS FROM THE SAMPLE - Surface of internal water passage

Electroplating materials were observed on the internal water passage surfaces of the samples under a non-destructive and unaided visual inspection. AS/NZS 4020: 2005 Appendix H and Extraction Temperature (20 ° C)

Extraction		Concentration of metals in the extract (µg / 1)		
		Cr-Chromium	Ni-Nickel	
Sample A	7 th	30	19	
Sample B	7 th	20	20	
	Requirement	≤ 50	≤ 20	
	Overall result	C	C	



Figure 1-Sample



Figure 3 - Surface of internal water passage




Figure 2- Sample disassembled

(* - Part /s which contact with water)



Figure 4 – Body marking