






PROJECT		REF		REV	ITEM CODE	
LOCATION		DATE			PAGE	

SANITARY WARE SPECIFICATION SHEET

Item Descriptions	SODUN (PRC) Ø35 x 600mm long white ABS coated aluminium grip grab rail ;BS12:1978 & BS882:1973 capable of carrying a static loading test 150kg ; test report PHY200012(2) ; complied with Barrier Free Access 2008	Illustration/ Drawing 
Dimensions	600 mm x Ø35 mm	 anti-slip
Model	S-8810-24	
Material/ Color	ABS Coated Aluminum/ White	
Manufacturer	SODUN (PRC)	
Source	Ka Shing Enterprises (H.K.) Limited Mr. Ivan Lau / Mr. GilmanYuen	
Contact Tel/Fax	(852) 2628-0661 / (852) 2490-2700	
E-mail	kashing.project@gmail.com	
Website	www.kashingehk.com	

Note:

* All information of the above is for the reference only. No prior notice is made if any changes.



AA Lab Ltd.

Flat I, 5/F, Fu Cheung Centre,
5-7 Wong Chuk Yeung Street,
Fotan, New Territories,
HONG KONG

Tel: (852) 37050140; Fax: (852) 37050141

www.aalab.com.hk

Client Ref. : --

Report No. : PHY200012(2)

Page 1 of 2

REPORT ON LOADING TEST OF GRAB BAR

Information Supplied by Client

Client : Ka Shing Enterprises (H.K.) Limited
Project : Loading test of grab bar - 150kg
Sample Description : 24 Inch of length grab handle
Model No. : S-8810-24

Laboratory Information

Lab. Sample I.D. : PHY200012/3
Date Received : 7/5/2020
Date Test Started : 11/5/2020
Date Test Completed : 11/5/2020
Test Method : General Specification 2013 Section 14 Ironmongery Clause 14.07(2)

Test Results

Lab Sample ID	Test Load (kg)	Duration (minute)	Visual damage (e.g. breakage, significant permanent deformation, etc)	Result
PHY200012/3	150	5	No visual damage	Pass

Test description: The grab handle was mounted on a concrete wall. A test load was applied vertically to the mid point of the handle for 5 minute which was then examined for any signs of damage.

Remarks : 1.) The test results relate only to the samples tested.



Checked by : M.C. Lam Date : 2/6/2020 Certified by : igor Date : 2/6/2020

Cheung Chi Ho, Igor
Dept. Head (Physical Testing)



AA Lab Ltd.


Flat 1, 5/F, Fu Cheung Centre,
5-7 Wong Chuk Yeung Street,
Fotan, New Territories,
HONG KONG

Tel: (852) 37050140; Fax: (852)37050141
www.aalab.com.hk


Client ref: --

Report No.: PHY200012(2)

Page: 2 of 2



Test Sample numbered PHY200012/3



Test configuration

*** End of Report ***

