







PROJECT		REF		REV	ITEM CODE	
LOCATION		DATE			PAGE	

## SANITARY WARE SPECIFICATION SHEET

Item Descriptions	SODUN (PRC) Ø35 x 780mm long white ABS coated aluminium grip grab rail ;BS12:1978 & BS882:1973 capable of carrying a <b>static loading test 150kg</b> ; test report PHY200012(2) ; complied with Barrier Free Access 2008	<p style="text-align: center;">Illustration/ Drawing</p>   <p style="text-align: center;">anti-slip</p>  
Dimensions	780 mm x Ø35 mm	
Model	S-8900	
Material/ Color	ABS Coated Aluminum/ White	
Manufacturer	SODUN (PRC)	
Source	Ka Shing Enterprises (H.K) Limited Mr. Ivan Lau / Mr. GilmanYuen	
Contact Tel/Fax	(852) 2628-0661 / (852) 2490-2700	
E-mail	kashing.project@gmail.com	
Website	www.kashingehk.com	

Note:

*\* All information of the above is for the reference only. No prior notice is made if any changes.*



**AA Lab Ltd.**

Flat I, 5/F, Fu Cheung Centre,  
5-7 Wong Chuk Yeung Street,  
Fotan, New Territories,  
HONG KONG

Tel: (852) 37050140; Fax: (852) 37050141

[www.aalab.com.hk](http://www.aalab.com.hk)

Client Ref. : --

Page 1 of 2

Report No. : PHY200012(4)

## **REPORT ON LOADING TEST OF GRAB BAR**

### **Information Supplied by Client**

Client : Ka Shing Enterprises (H.K.) Limited  
Project : Loading test of grab bar - 150kg  
Sample Description : Plastic wrapped foldable grab bar (包膠傷殘扶手)  
Model No. : S-8900

### **Laboratory Information**

Lab. Sample I.D. : PHY200012/2  
Date Received : 7/5/2020  
Date Test Started : 12/5/2020  
Date Test Completed : 12/5/2020  
Test Method : General Specification 2013 Section 14 Ironmongery Clause 14.07(2)

### **Test Results**

Lab Sample ID	Test Load (kg)	Duration (minute)	Visual damage (e.g. breakage, significant permanent deformation, etc)	Result
PHY200012/2	150	5	No visual damage	Pass

Test description: The grab bar was mounted on a concrete wall. A test load was applied vertically to the mid point of the bar for 5 minute which was then examined for any signs of damage.

Remarks : 1.) The test results relate only to the samples tested.

Checked by : M.K. Lam Date : 2/6/2020 Certified by : Igor Date : 2/6/2020

Cheung Chi Ho, Igor  
Dept. Head (Physical Testing)





**AA Lab Ltd.**

Flat I, 5/F, Fu Cheung Centre,  
5-7 Wong Chuk Yeung Street,  
Fotan, New Territories,  
HONG KONG

Tel: (852) 37050140; Fax: (852) 37050141  
[www.aalab.com.hk](http://www.aalab.com.hk)

Client ref: --  
Report No.: PHY200012(4)

Page: 2 of 2



Test Sample numbered PHY200012/2



Test configuration

\*\*\* End of Report \*\*\*

