

## Ka Shing Enterprise (H.K.) Ltd.

ROOM 1706 NEW TERRITORIES TSUEN WAN HO LIK CENTRE, 66A SHA TSUI ROAD Tel:26280661 Fax: 24902700 Email: project@kashingehk.com Website: www.kashingehk.com




PROJECT	REF	REV	ITEM CODE	
LOCATION	DATE		PAGE	

## **SANITARY WARE SPECIFICATION SHEET**

Item Descriptions	LIXIL / INAX (Japan) automatic chrome		
	plated 6LPF Toilet Sensor Flush Valve with		
	manual button & 24 hours auto starts		
	function, 220V AC Supply		
Dimensions	L160 x W160 x D140 mm		
Model	OKCH-500S		
Finish	Chrome Plated		
Brand	LIXIL / INAX (JAPAN)		
Source	Ka Shing Enterprises (H.K) Limted		
	Mr. Ivan Lau / Mr. GilmanYuen		
Contact Tel/Fax	(852) 2628-0661 / (852) 2490-2700		
E-mail	project@kashingehk.com		
Website	www.kashingehk.com		

Proudct Code	OKCH-500S		
Sensor Type	Infrared		
Detect Distance	500mm~800mm Preset出厂设定 800mm / Kodak Gray Card		
Water Supply Pressure	0.1 ~ 0.75Mpa (Internal Dimension Should be no less than 25mi		
Inlet Pipe	G1"		
Outlet Pipe	D31.8 Brass Tube		
Flush Delay	5 Seconds After Leaving		
Environment Temperature	1℃ ~ 55℃		
Working Temperature	1°C ~ 45°C		
Detect Time	≥ 3 Seconds		
Flush Time	3~10Seconds		
Flush Volume	6L		
Environment protection	With a flush when 24 Hours with no detection		
water supply	Municipal Water / Sea Water		



Note:			

<sup>\*</sup> All information of the above is for the reference only. No prior notice is made if any changes.



## 水務署 Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 Our ref. 來函檔號

Your ref.

: (8) in WSD 3321/19 T/J(1072/2019)

電話

Tel. 傳真

将具 Fax. : 2824 0578

14 April 2020



Dear Sir,

## Approval of "INAX" Sensor Flush Valve (General Acceptance No. C20200243F)

Your letter ref. WRC/2119 dated 7 November 2019 and subsequent submissions received by this department up to 16 March 2020 refer.

Having considered the test report ref. J24689r3 issued on 10 March 2020 by Nutek Systems (HK) Ltd., this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer:

INAX

Country of Origin:

the Mainland of China

Brand:

INAX

**Details of Fitting:** 

1" Sensor flush valve for WC

Model:

OKCH-500S

**Body Markings:** 

**INAX** 

**Expiry Date:** 

23 October 2024





As the fitting has not been tested for use in contact with water intended for human consumption, the fitting can only be used in flushing water

plumbing system.

This Authority hereby permits the use of the above fitting in flushing water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

> "Installation of filter before flushing valve is required. Without the filter, the flushing valve is liable to leak. The installed filter need frequent inspection and cleaning to maintain flushing supply. Normally only public toilets with good management system for maintenance would be considered."

> "A stop cock or gate valve must be installed at the upstream of the fitting for manual isolation of water supply."

> "The design flushing volume of the flushing valve should be compatible with the toilet bowl to ensure that effective clearance can be achieved by a single flush of water."

> "Flushing valve should be used within the range of working pressures specified by the manufacturer." AND

> "Installation of electronic opening and closing sanitary tapware should also comply with the requirements of Electrical & Mechanical Services Department."

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in flushing water plumbing systems.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,

(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82 ] - without catalogue

ME/MC ] - with soft copy only