



PROJECT		REF		REV	ITEM CODE	
LOCATION		DATE			PAGE	

SANITARY WARE SPECIFICATION SHEET

Item Descriptions	Schleich (PRC) Single lever basin mixer; nominated flow rate 4.4 L/min in WELS Grade 1 ; Registration No. TM 19-0102; CBS EN 1286: 1999; BS EN 1982:2008; AS/NZS 4020: 2005 PLU2.M510; BS 5412: 1996 & BS 5779: 1979 AS/NZS 4020: 2005: App. I CI. 6.3; test report J2358Ar1	Illustration/ Drawing														
Model	S-019															
Finish	Chrome Plated															
Manufacturer	Schleich (PRC)															
Source	Ka Shing Enterprises (H.K.) Limited Mr. Ivan Lau / Mr. Gilman Yuen															
Contact Tel/Fax	(852) 2628-0661 / (852) 2490-2700															
E-mail	project@kashingehk.com															
Website	www.kashingehk.com															
<table border="1" style="margin-top: 10px;"> <thead> <tr> <th>Dynamic Flow Pressure (kPa)</th> <th>Reading 1st (L/Min)</th> </tr> </thead> <tbody> <tr><td>50</td><td>2.25</td></tr> <tr><td>150</td><td>3.65</td></tr> <tr><td>250</td><td>4.5</td></tr> <tr><td>350</td><td>5.03</td></tr> <tr><td>500</td><td>5.65</td></tr> <tr><td>600</td><td>6.22</td></tr> </tbody> </table> <p style="text-align: center;">*1 bar = 100 kPa*</p>		Dynamic Flow Pressure (kPa)	Reading 1st (L/Min)	50	2.25	150	3.65	250	4.5	350	5.03	500	5.65	600	6.22	
Dynamic Flow Pressure (kPa)	Reading 1st (L/Min)															
50	2.25															
150	3.65															
250	4.5															
350	5.03															
500	5.65															
600	6.22															

Note:

* All information of the above is for the reference only. No prior notice is made if any changes.

註冊號碼 (Registration No.): TM 19-0102



自願參與用水效益標籤計劃 - 水龍頭
Voluntary Water Efficiency Labelling Scheme - Water Taps

Certificate of Registration 註冊證書



茲證明
This is to certify that
Ka Shing Enterprises (H.K) Ltd.

將下列水龍頭在本計劃內註冊：
has registered the following water tap under this scheme :

牌子 / Brand	:	Schleich
型號 / Model	:	S-019
種類 / Type	:	Mixing
原產地 / Country or Region Origin	:	China

在用水效益標籤上展示的標誌 <i>Symbolic Presentation on the Water Efficiency Label</i>	:		滴水點 <i>Water droplet(s)</i>
用水效益級別 <i>Water Efficiency Grade</i>	:	1	
耗水量 <i>Water Consumption</i>	:	4.4	公升/分鐘 <i>litres/minute</i>

簽發日期：
Date of Issue: 25 March 2019

 水務署
Water Supplies Department



水務署署長(張業駒代行)
for Director of Water Supplies



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/19 T/J(699/2019)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

19 August 2019

Ka Shing Enterprises (HK) Ltd
Unit A, 3/F., 30-38 Tsuen King Circuit,
Waylee Ind. Centre, Tsuen Wan,
N.T., Hong Kong

(Attn.: Mr Ivan LAU)



Dear Sir,

**Approval of "SCHLEICH" Basin Mixer
(General Acceptance No. C20190421)**

Your letter dated 16 July 2019 and subsequent submission received by this department on 7 August 2019 refer.

Having considered the test report ref. J23581Ar1 issued on 31 July 2019 by Nutek System (HK) Limited, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: 廣東省鶴山市址山東溪開發區江毅水暖廠
Country of Origin: the Mainland of China
Brand: Schleich
Details of Fitting: 3/8" Single lever basin mixer
Model: S-019
Body Markings: SCHLEICH®
Expiry Date: 21 November 2023



This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fitting shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply."

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless otherwise specified.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only

General Acceptance No. C20190421