




PROJECT		REF		REV	ITEM CODE	
LOCATION		DATE			PAGE	

SANITARY WARE SPECIFICATION SHEET

Item Descriptions	Kita (PRC) Desk mounted precise Infra-red sensor mixer with thermostatic variants 1/2 in DC or AC Supply ; nominated flow rate 3.2 L/min in WELS Grade 1 ; Registration No. TN 20-0193 ; complies with:BS EN 15091: 2013; BS EN 1982: 2008; BS EN 12164: 2016; BS 6920-3: 2000; BS 6920-2.6: 2000 + A2: 2014 & AS/NZS 4020:2005; test report J27556A
Model	KSE-1003
Dimensions	L172 x W55 x H130mm
Finish	Chrome Plated
Manufacturer	Kita (PRC)
Source	Ka Shing Enterprises (H.K.) Limited Mr. Ivan Lau / Mr. Gilman Yuen
Contact Tel/Fax	(852) 2628-0661 / (852) 2490-2700
E-mail	project@kashingehk.com
Website	www.kashingehk.com

Illustration/ Drawing

Sensor	Infrared Sensor
Valve	Solenoid Valve
Power	battery or 200V AC
Operating range	Auto
Inlet	G 1/2"
Temperature Range	1-60 °C
Water pressure	0.05 MPa ~ 0.8 MPa
Material	Brass
Surface	Chrome Plated
Origin of Country	PRC



Note:

* All information of the above is for the reference only. No prior notice is made if any changes.

註冊號碼 (Registration No.): TM 22-0193



自願參與用水效益標籤計劃 - 水龍頭
Voluntary Water Efficiency Labelling Scheme - Water Taps

Certificate of Registration
註冊證書




茲證明
This is to certify that

Ka Shing Enterprises (H.K.) Limited

將下列水龍頭在本計劃內註冊：
has registered the following water tap under this scheme :

牌子 / Brand	:	Kita + Schleich
型號 / Model	:	KSE-1003 + S-FR4L
種類 / Type	:	Mixing
原產地 / Country or Region Origin	:	China (Mixer & Flow Controller)

在用水效益標籤上展示的標誌 <i>Symbolic Presentation on the Water Efficiency Label</i>	:		滴水點 <i>Water droplet(s)</i>
用水效益級別 <i>Water Efficiency Grade</i>	:	1	with additional merit*
耗水量 <i>Water Consumption</i>	:	2.9	公升/分鐘 <i>litres/minute</i>

*with additional merit of "Automatic closing mechanism"

簽發日期: 7 October 2022
Date of Issue:

 水務署
Water Supplies Department



水務署署長(林麗恒代行)
for Director of Water Supplies



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (2) in WSD 3321/2022 T/J(794/2022)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

27 July 2022

Ka Shing Enterprises (HK) Ltd
Unit A, 3/F., 30-38 Tsuen King Circuit,
Waylee Ind. Centre, Tsuen Wan,
N.T., Hong Kong



(Attn.: Mr Ivan LAU)

Dear Sir,

**Approval of "KITA" Sensor Mixer
(General Acceptance No. C20220709)**

Your letter dated 30 June 2022 refers.

Having considered the test report ref. J27556A issued on 29 June 2022 by Nutek Systems (HK) Ltd., this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: 廣東省開平市水口鎮聯強衛浴
Country of Origin: the Mainland of China
Brand: Kita
Details of Fitting: 1/2" Deck mounted sensor mixer
Model: KSE-1003
Body Markings: Nil
Expiry Date: 21 June 2027



This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fitting shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply."

"A stop cock or gate valve must be installed at the upstream of the fitting for manual isolation of water supply." AND

"The main voltage operated sensor valve should comply with the electricity safety regulation for applications in bathroom, toilet etc."

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless otherwise specified.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(YAU Hau Yin)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only

General Acceptance No. C20220709