

Grab Bar



SANITARY WARE SPECIFICATION SHEET


Model: 802-FL690

Descriptions: SODUN (PRC) Ø32 x 600 x 690mm long stainless steel 304 L-shape grab bar in satin finish ; capable of carrying a static loading test 150kg ; test report J29853;complied with Barrier Free Access 2008

Dimensions: 32mm dia x 600 x 690 mm long

Finish : Stainless Steel

Manufacturer: SODUN (PRC)



* All information of the above is for the reference only. No prior notice is made if any changes.



Ka Shing Enterprise (H.K.) Ltd.

ROOM 1706 NEW TERRITORIES TSUEN WAN HO LIK CENTRE, 66A SHA TSUI ROAD
Tel:26280661 Fax: 24902700
Email: project@kashingehk.com
Website: www.kashingehk.com

Ivan / Horace 26280661

E/ project@kashingehk.com

W/ <https://www.kashingehk.com/>

Test Report

TITLE : Loading test
REPORT NO. : J 29853
DESCRIPTION OF SAMPLE : Grab Bar
SAMPLE SUBMITTED BY : Ka Shing Enterprises (H.K.) Limited
Unit A, 3/F, 30-38 Tsuen King Circuit,
Waylee Industrial Centre, Tsuen Wan, N.T.
Chai Wan Kok, N.T. Hong Kong
BRAND : Sodun
COUNTRY OF ORIGIN : CHINA
MODEL : 802-FL690
METHOD OF TESTS : Loading test
PERIOD OF TESTS : 10 May, 2024

RESULTS: (apply only to the sample tested)

1. Load test

The sample was installed onto a concrete wall in its normal application (cement to GB 175-2007). A test load was applied to the mid point of the sample which was then examined for any signs of damage.

	Weight/ downward load (kg)	Test duration (min)	Break/failure/ deflection/crack	Remark
Sample	150	30	No	PASS
Required	150	30	No	--

Note:

The sample is capable of carrying the static load as per requirement of Clause 53, Design Manual: Barrier Free Access 2008 (2021 Edition).

Date: 17 May, 2024

Authorized Signature:


Lam Kwai Wan, Terry
(Operations Manager)

Nutek Systems is a testing agency,
accepted by the Water Supplies
Department, for testing water supply
fittings.

REPORT NO.: J 29853



Figure 1 - Sample

- End of report-

Page 2 of 2