## Disable wash basin



## SANITARY WARE SPECIFICATION SHEET

Model: KSE0327.400(Basin) 899V (Bottle trap)

> CN-038 (Tap) CP-18A (Angle valve) NX-1103 (Waste) BL-44 (Flexible hose)

Descriptions: Casatino (PRC) "Sleek" Vitreous china wall hung wash basin with 1-1/4 inch plastic anti-syphon bottle trap; chrome

> plated brass 1-1/4 inch. waste slotted and elbow action tap for disabled; 1/2" x 1/2" flexible hose & angle valve; nominated flow rate 3.4 L/min in WELS Grade 2; Registration No. TN 19-0057; complies with: BS EN 200: 2008; BS EN 1982: 2008 & AS/NZS 4020: 2005; BS EN 200: 2008; BS EN 1982: 2008; BS EN 12164: 2016 & AS/NZS 4020: 2005 PLU1. M680.7; BS 1010: Part 2: 1973 ;test report J25761;complied with BFA2008

L555 x W320 x H125 mm Vitreous China Dimensions: Material:

Manufacturer: Casatino (PRC) Color: White



<sup>\*</sup> All information of the above is for the reference only. No prior notice is made if any changes.



## Ka Shing Enterprise (H.K.) Ltd.

ROOM 1706 NEW TERRITORIES TSUEN WAN HO LIK CENTRE, 66A SHA TSUI ROAD Tel:26280661 Fax: 24902700 Email: project@kashingehk.com Website: www.kashingehk.com



## 自願參與用水效益標籤計劃-水龍頭 Voluntary Water Efficiency Labelling Scheme -Water Taps





茲證明 This is to certify that



將下列水龍頭在本計劃內註冊: has registered the following water tap under this scheme:

/ Brand

原產地

/ Model

/ Type

/ Country or Region Origin

KITA

CN-038

Non-mixing China

在用水效益標籤上展示的標誌

Symbolic Presentation on the Water Efficiency Label

3.4

滴水點

Water droplet(s)

用水效益级别

Water Efficiency Grade

耗水量

Water Consumption

2

公升/分鐘

簽發日期: Date of Issue:


16 May 2019



H

水務署 Water Supplies Department

水務署署長(張業駒代行) for Director of Water Supplies



160

200



### 水務署

### **Water Supplies Department**

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 Our ref. 來函檔號

Your ref.

(4) in WSD 3321/2021 T/J(53/2021)

電話

Tel.

傳真 Fax.

: 2824 0578

5 March 2021



Dear Sir,

### Approval of "KITA" Basin Tap (General Acceptance No. C20210216)

Your letters dated 16 December 2020 and 25 January 2021 refer.

Having considered the test report ref. J25761 issued on 26 November 2020 by Nutek System (HK) Limited, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer:

廣東省鶴山市址山東溪開發區江毅水暖廠

Country of Origin:

the Mainland of China

**Brand:** 

Kita

**Details of Fitting:** 

1/2" Single lever basin tap

Model:

CN-038

**Body Markings:** 

Website: www.kashingehk.com

Kita®

**Expiry Date:** 

16 November 2025







Ka Shing Enterprise (H.K.) Ltd.

ROOM 1706 NEW TERRITORIES TSUEN WAN HO LIK CENTRE, 66A SHA TSUI ROAD Tel:26280661 Fax: 24902700 Email: project@kashingehk.com

This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless otherwise specified.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,

(Roger WONG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82 ] - without catalogue ME/MC ] - with soft copy only

General Acceptance No. C20210216





# **NUTEK SYSTEMS, LTD.**

Unit B, 13/F., Block A, Universal Ind. Ctr., 23-25 Shan Mel Street, Fo Tan, Shatin, N.T., Hong Kong. Tel: (852) 2605 5736 Fax: (852) 2692 0798 E-mail: nutelk@nuteksystems.com

TITLE : Testing of Trap

OUR REFERENCE NO. : J18797

DESCRIPTION OF SAMPLE : 32mm Plastic Anti-syphonic bottle trap

SAMPLE SUBMITTED BY

BRAND : DAIMLER

MODEL : 899V

BODY MARKINGS : DAIMLER BS3943 ANTI-SYPHONIC TRAP

METHOD OF TEST : BS3943: 1979

PERIOD OF TESTS : 23rd Apr., 2015 to 11 May, 2015

RESULTS: - (apply only to the sample tested)

1. DIMENSIONS (all dimensions are in millimetres unless otherwise stated)

		Sample
Nominal size		32
Depth of water sea	1	85.0
Minimum cross-sectional area of waterway (mm²)		881
Length	A	188
	В	75.5
	C	126

2. HYDROSTATIC PRESSURE TEST (external leakage and inlet attachment test)

	Test pressure (bar)	Duration (s)	Remark
Sample	0.5	15	Pass
BS Requirement	0.5	15	1

### 3. WATER SEAL TEST

	Test pressure (Pa)	Duration (s)	Remark	
Sample	690	10	Pass	
BS Requirement	690 ± 20	10	/	

#### 4. FLOW OF WATER TEST

	Water flow rate (litre/min)	Remark
Sample	66.2	Pass
BS Requirement	40 min.	/

/.....P.2

NUTEK SYSTEMS, LTD.

Certified True Copy



## Ka Shing Enterprise (H.K.) Ltd.

#### OUR REFERENCE NO.J 18797 (P.2)



### 5. INTERNAL CLEARANCE TEST

NUTEK SYSTEMS, LTD. Certified Truo Copy

Pass; the trap is capable of accommodating the passage of a steel ball of diameter 10mm, when tested by passing the ball right through from inlet to outlet.

#### 6. IMPACT TEST

Trap component	Impact energy (J)	Weight of striker (kg)	Falling height (m)	Remark
Body	21	1.8	1.19	Pass
Coupling nuts	14	1.8	0.79	Pass
Other parts	7	1.8	0.4	Pass

### 7. ELEVATED TEMPERATURE CYCLING

	Hot water temperature (°C)	Cold water temperature (°C)	No. of cycles	Sign of leakage	Remark
Sample	92 - 93	20	1500	Nil	Pass
BS Requirement	93 ±1	1	1500	Nil	1

#### 8. RESIDUAL STRESS

The sample was immersed in a boiling solution of 0.2% by mass of sodium alkyl aryl sulphonate detergent, with 0.5% by mass margarine for 30 minutes.

Sample	Acceptance standard
1) sample showed no visible distortion or crack	1) no crack, no degeneration
the function of maintaining the water seal is not affected	trap not distorted to such a degree that its function of maintaining the water seal is affected

#### 9. SUMMARY OF RESULTS (apply only to the sample tested)

Dimensions Satisfactory Hydrostatic pressure test Satisfactory Water seal test Satisfactory Flow of water test Satisfactory Internal clearance test Satisfactory Impact test Satisfactory Elevated temperature cycling Satisfactory Residual Stress Satisfactory

Date: Description of the land of the land

WONG K.S., Sunny (Director)

NUTEK SYSTEMS, LTD. Unit 8, 13/F, Block A, Universal Ind. Ctr., 23-25 Shan Mei Street, Fo Tan, Shatin, N.T., Hong Kong, Tel: (852) 2605 5736 Fax: (852) 2692 0798 E-mail: nutek@nuteksystems.com



Ka Shing Enterprise (H.K.) Ltd.



### 水務署

### **Water Supplies Department**

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 Our ref. 來函檔號 Your ref.

(4) in WSD 3321/2022 T/J(438/2022)

電話

Tel.

傳真 Fax

: 2824 0578

10 June 2022

Ka Shing Enterprises (HK) Ltd Unit A, 3/F., 30-38 Tsuen King Circuit, Waylee Ind. Centre, Tsuen Wan, N.T., Hong Kong

(Attn.: Mr Ivan LAU)

Dear Sir,

Approval of "KITA" Angle Valve (General Acceptance No. C20220496)

Your letters dated 21 April 2022 and 14 May 2022 refer.

Having considered the test report ref. RKSH008-1r2 issued on 13 May 2022 by Ideal Test Consultants Ltd., this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer:

玉環同泰銅業有限公司

Country of Origin:

the Mainland of China

Brand:

Kita

**Details of Fitting:** 

1/2" x 1/2" Copper alloy angle valve

Model:

CP-18A

**Body Markings:** 

KITA

**Expiry Date:** 

20 March 2027







Ka Shing Enterprise (H.K.) Ltd.

ROOM 1706 NEW TERRITORIES TSUEN WAN HO LIK CENTRE, 66A SHA TSUI ROAD Tel:26280661 Fax: 24902700 Email: project@kashingehk.com Website: www.kashingehk.com

This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,

(YAU Hau Yin) for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82 ] - without catalogue ME/MC ] - with soft copy only

General Acceptance No. C20220496

Website: www.kashingehk.com

